



Goverment of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Purulia Fire Station, Ranchi Road, Purulia, Pin:- 723101

Memo No.:FSR/211862406300003794

Date : 19-09-2025

From :
Divisional Fire Officer
Purulia Division,
West Bengal Fire & Emergency Services

To :
KUSHAL EDUCATION FOUNDATION
Vill- Chharah - Dumdumi, P.O- Dumdumi, Mouza- Dumdumi, P.S- Purulia (M), Dist- Purulia, Pin- 723147, WB

Sub : Fire Safety Certificate for the occupancy of an existing construction of G+2 storied building under group Educational in the name and style as " of Kushal Educational Foundation" (Delhi World Public School) situated at Vill:-Dumdumi, P.O:-Dumdumi, Plot No:-6020,6021,6022, Kh No:- 63, 379, 390669 and 119, L.S.Khatian No :901, , Mouza :- Dumdumi,,P.S:-Purulia(M),, Dist:-Purulia, Pin-723147(WB).

This is in reference to your AIN 211892506300008211 dated 03-Sep-2025 regarding Fire Safety Certificate for the occupancy of an existing construction of G+2 storied building under group Educational in the name and style as " of Kushal Educational Foundation" (Delhi World Public School) situated at Vill:-Dumdumi, P.O:-Dumdumi, Plot No:-6020,6021,6022, Kh No:- 63, 379, 390669 and 119, L.S.Khatian No :901, , Mouza :- Dumdumi,,P.S:-Purulia(M),, Dist:-Purulia, Pin-723147(WB)..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

1. All the Fire Safety measures provided in the building must be kept in good working condition all the time to ensure fire & life safety of the building.
2. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
3. The Interior finish decoration of buildings shall be made with low flame spread material



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300008211

confirming to the I.S. Specification.

4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the buildings shall be strictly maintained.
5. Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
6. A Fire control room including a closed-circuit TV system shall have to be maintained which observe all the floors of the building.
7. The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the Building.
8. The employees and security staff shall be conversant with installed firefighting equipment of the buildings and to operate in the event of fire and testing.
9. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the buildings.
10. A trained Fireman shall be maintained round the clock for fire safety of the building.
11. First Aid firefighting system shall be provided as per I.S. specifications.
12. Arrangement shall have to be made for regular checking, testing, and maintenance of all The Fire Fighting installation in the buildings to keep them in perfectly good working Condition at all the times.
13. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance registers.
14. Electrical audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance registers, and Electrical Ducts shall have to be sealed vertically and horizontally in proper manner immediately.
15. One same capacity Fire Pump installed for back up.
15. The Fire Safety Certificate is valid for a period of three years from the date of issue. And has to be renewed after three years certifying about the satisfactory services, performance of all the Life Safety arrangements installation of the building.
16. Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire Safety Certificate will be treated as canceled.

Valid Upto : 17-Sep-2028

Memo No.:FSR/211862406300003794



Signature Not Verified

Digitally Signed.
Name: SWAPAN KUMAR DAS
Date: 19-Sep-2025 20:37:31
Reason: D-Sign
Location: E-District

DIVISIONAL FIRE OFFICER

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300008211